

Fire Safety in Oil Storage Installations

Thomas Leonard BE, MEngSc, MIEI

Chartered Engineer

Associate Partner, Byrne Ó Cléirigh Consulting



Introduction

- ❑ Fire Safety in Bulk Flammable Stores:
 - Risks of major accidents
 - Measures to protect against major accidents
 - Design and operation of a petroleum storage installation
 - Fire fighting policy / emergency response planning

- ❑ Case studies:
 - Dublin Port
 - Sullom Voe
 - Buncefield

Concept of Risk

- ❑ Hazard
 - Intrinsic property of a dangerous substance or physical situation
- ❑ Consequence
 - The outcome of an event as a loss, injury, disadvantage or gain
- ❑ Probability
 - The likelihood of a specific event or outcome
- ❑ Risk
 - A combination of Probability and Consequence

Hazard Identification and Risk Assessment

- ❑ Formal assessment of all foreseeable major accident scenarios.
 - Loss to aquatic environment
 - Fire
 - Explosions
- ❑ Assess Severity and Likelihood of each scenario → Risk.
- ❑ Thresholds for assessing the levels of Risk.
- ❑ Additional improvements where necessary.

Matrix used for Risk Assessment

		Severity of Consequences					
		0 Negligible	1 Minor	2 Appreciable	3 Severe	4 Very Severe	5 Catastrophic
1	Virtually Impossible	0 Trivial Risk	1 Trivial Risk	2 Trivial Risk	3 Trivial Risk	4 Trivial Risk	5 Minor Risk
2	Improbable	0 Trivial Risk	2 Trivial Risk	4 Trivial Risk	6 Minor Risk	8 Minor Risk	10 Moderate Risk
3	Unlikely	0 Trivial Risk	3 Trivial Risk	6 Minor Risk	9 Moderate Risk	12 Substantial Risk	15 Priority Risk
4	Infrequent	0 Trivial Risk	4 Trivial Risk	8 Minor Risk	12 Substantial Risk	16 Priority Risk	20 Priority Risk
5	Occasional	0 Trivial Risk	5 Minor Risk	10 Moderate Risk	15 Priority Risk	20 Priority Risk	25 Priority Risk
6	Frequent	0 Trivial Risk	6 Minor Risk	12 Substantial Risk	18 Priority Risk	24 Priority Risk	30 Priority Risk

Risk of Major Fire

- ❑ Use of Literature Data to calculate probabilities (TNO, HSE).
- ❑ Calculation is site-specific.
- ❑ Probability depends on number of tanks, pipelines, throughput etc as well as on the measures in place.
- ❑ A major fire is a credible scenario for any installation involved in the Bulk Storage of Flammable Materials.

Risk of Major Explosion

- ❑ Risk of an explosion is not so well established.
- ❑ Not previously considered credible for spills of Flammable Liquid.
- ❑ Buncefield showed that it could happen.
- ❑ Circumstances of Buncefield Incident still under investigation.
- ❑ Authorities will advise on the risk of this event.

Impacts of Major Fires

- ❑ High Heat Fluxes to other tanks and equipment.
- ❑ Risk to personnel in vicinity of the fire.
- ❑ Impact depends on the scale of the fire:
 - Tank Fire
 - Bund Fire
 - Fire resulting from Catastrophic Tank Failure

Examples of Tank Fires



Example of a Bund Fire



Example of Catastrophic Failure



Example of Catastrophic Failure



Consequence Modelling of Fires

- ❑ Software Packages or literature data.
- ❑ Impact of fire depends on a number of parameters:
 - Surface area of fire
 - Product involved
 - Wind speed
 - Distance to receptor
- ❑ Model plots heat flux against distance.




Consequence Modelling of Fires – Endpoints


- Heat Radiation Levels (kW/m²):
 - 4 kW/m²: Specified Area. Safe access for fire fighters.
 - 6.3 kW/m²: Maximum safe level at an emergency exit.
 - 8 kW/m²: Threshold level for protective cooling.

- Thermal Dose Levels ((kW/m²)^{4/3}.s):
 - 500 TDU: Threshold of fatality
 - 1000 TDU: 1% fatality
 - 1800 TDU: 50% fatality


Consequence Modelling – calm weather



Consequence Modelling – flame tilt



Consequence Modelling – flame tilt



Impacts of Major Explosions

- ❑ Overpressure levels:
 - 30 mbar: Specified Area. Limited minor structural damage
 - 70 mbar: Damage to roof of storage tank
 - 150 mbar: Partial collapse of walls and roofs of houses
 - 1000 mbar: Collapse of supporting structure of round storage tank
- ❑ Not straightforward to model explosion of flammable liquid.
- ❑ Buncefield Investigation.

Measures to Protect against Fires / Explosions

- ❑ Measures to prevent loss of containment:
 - Level Indicator with independent High Level Alarm
 - Maintenance inspections
 - Impact protection

- ❑ Measures to reduce risk of ignition:
 - Hazardous Area Zoning
 - Electrical equipment to be in compliance with ATEX
 - Permit-to-work system in hazardous areas


Measures to Protect against Fires / Explosions

- ▣ Measures to reduce the impact of a fire:
 - Tank Spacing
 - Bund Design
 - Fire Fighting Plan
 - On Site and Off Site Resources
 - Site location (for new facilities)

Design of Petroleum Storage Installations

- ❑ Bulk Storage Regulations, 1979.
- ❑ New sites must also take account of codes and standards, e.g. IP and NFPA Codes.
 - Tank Spacing
 - Bund Capacity (110% rule, max inventory per bund)
 - Distances to boundaries and non-process equipment
- ❑ Existing sites may not be able to comply fully with new Codes.

Sample Site Layout (from HSG 176)



Developing a Fire Fighting Policy

- ❑ Examine the fire scenarios that can arise:
 - Tank Fire
 - Bund Fire
 - Catastrophic failure
 - others

- ❑ Calculate the water and foam requirements (IP 19, NFPA):
 - Foam application to fire
 - Water to engulfed tanks
 - Water to adjacent tanks

Developing a Fire Fighting Policy

- ❑ Compare requirements with the available resources:
 - Flow rates, pressures in mains
 - Foam stocks
 - Ability of system to apply resources where needed
- ❑ Maximum Feasible Extinguishment:
 - Fight a scenario with fixed or semi-fixed equipment
 - Fight a scenario with mobile equipment
 - Pump product out, let tank burn and protect adjacent tanks
- ❑ Upgrade facilities where necessary.

Case Study – Fire Fighting Study at Dublin Port

- ❑ Survey of 15 sites.
- ❑ Large inventory of hazardous substances:
 - 9,000 m³ LPG
 - 115,000 m³ Gasoline and Kerosene
 - 154,000 m³ Gas Oil / DERV / HFO (Class III(2))
- ❑ Project to review fire scenarios and response options.
- ❑ Recommend appropriate strategy for medium to long term.

Aerial Picture of Dublin Port



Scope of Project

- ❑ Review existing arrangements against best practice.
- ❑ Assess potential worst case fire scenarios at each location (15 sites, COP, Jetties and truck/rail movement).
- ❑ Assess capacity of existing facilities to cope with the credible scenarios.

Scenarios Examined

- ❑ Flash fire or explosion involving LPG:
 - Event would be over before response could be mounted
 - Aftermath likely to be similar to catastrophic tank failure
- ❑ Fire involving flammable liquid storage:
 - Full roof fire in a single tank
 - Full bund fire, possibly involving several tanks (including Class III)
 - Catastrophic tank failure with ignition
- ❑ Other scenarios.

Methodology

- ❑ Modelling of major fire scenarios.
- ❑ Assessment of resources required to attack these scenarios.
- ❑ Determined current capabilities at the Port.
- ❑ Comparison of recommended requirements with capabilities:
 - Water supply and foam stocks
 - Ability of on-site & DFB systems to apply water and/or foam
- ❑ Develop Policy.
- ❑ Make recommendations on Fire Protection System.

Results

- Tank Fires:
 - Sufficient foam and water supply in place, in theory
 - Not easy to apply for tanks without fixed drenching systems
 - Foam storage arrangements unsuitable for a large monitor
- Bund Fires / Catastrophic Tank Failure:
 - Insufficient foam and water resources in place to extinguish

Catastrophic Failure with Running Pool Fire

- ❑ Fire covering a large area
- ❑ Impractical to provide the level of foam and water required:
 - Water required at nearly 4 tonnes/second
 - Fire main would need to be greater than 1 m diameter
 - Eight tankers, each holding 30 m³ foam, required on standby
- ❑ Access to mount attack impossible, even if equipment available.
- ❑ Not reasonable to extinguish – plan to prevent escalation.

Two Policy Options

□ Deal with All Tank Fires:

- Fixed foam systems on Class I & II tanks
- Drencher systems on Class I & II and some Class III tanks
- Portable foam/water monitors for first response
- Upgrades to mains system
- One high capacity foam monitor

□ Deal with all Bund Fires:

- Two high capacity foam monitors
- Additional foam stocks
- New fire-water ring main (450 mm)



Case Study – Sullom Voe

- ❑ Located in the Shetland Islands, off the coast of Scotland.
- ❑ Consortium arrangement: Managed by BP.
- ❑ Capacity c.1.4 million m³ crude.
 - Crude: 16 tanks
 - LPG: 4 spheres
- ❑ Terminal throughput of c.800 thousand bpd.

Site Layout



Arrangements at Sullom Voe

- ❑ Dedicated Emergency Response Group in place.
- ❑ Recent review of Fire Fighting Policy.
- ❑ Upgrades to Fire Fighting Systems to extinguish full roof fires:
 - Risk of boil over in crude tanks
 - Importance of facility
- ❑ Also decided to reduce inventory levels in propane tank.


Case Study – Buncefield Incident

- ❑ Depot stored Gasoline, Kerosene, Diesel and other fuels.
- ❑ Site capacity of c.275 million litres.
- ❑ Critical point on UK Oil Pipeline network.
- ❑ Throughput – 8% of UK oil, 40% of aviation fuel to Heathrow.

Description of Event

- ❑ Overfilling of Gasoline tank:
 - Delivery commenced at c. 19:00 on 10th December 2005
 - Level gauge unchanged from 3:00 although delivery continued
 - Product overfill commenced about 5:20
 - First explosion at 6:01, followed by further explosions
- ❑ Resulting fire engulfed 22 storage tanks.
- ❑ Low number of injuries, no fatalities.


Buncefield Site Layout



Description of Event

- ❑ Free fall of product promoted formation of rich fuel/air mixture:
 - Some product flowed over deflector plate
 - Much of the deflected product hit a wind girder
- ❑ Fuel/air mist was heavier than air.
- ❑ Several ignition sources.
- ❑ Overpressures much higher than would have been predicted:
 - Damage to nearby car park suggests 700 – 1000 mbar
 - Expected overpressures would be 20 – 50 mbar

Pattern of Fuel Dispersion



Hazards Associated with the Fire



Hazards Associated with Smoke



Fire Fighting Response

- ❑ Response provided by Herfordshire plus 31 other Fire Brigades.
- ❑ Over 700,000 litres of foam concentrate used.
- ❑ 68 million litres of water used.
- ❑ Dynamic response:
 - Environmental considerations (containment of run off)
 - Change of wind direction
 - Re-ignition of tanks / bunds
 - Problems with water and foam supplies



Containment of Run Off

- ❑ Some loss of containment from bunds.
- ❑ Following event, contaminated firewater removed from the site.
- ❑ Further removal of contaminated water (rainfall and cleaning).
- ❑ Water moved to storage facilities pending treatment.
- ❑ Loss of 800,000 litres contaminated water from storage facility.

Safety Alerts issued by HSE

❑ February 2006

- Review operations, plant, training, procedures etc
- Ensure appropriate measures in place for loss of containment

❑ July 2006

- Problem with overflow protection
- TAV level switches tested by adjusting lever at head of switch
- Must return to correct position and lock in place

Safety Alerts issued by HSE

❑ October 2006

- Operator checks for pipeline transfers
- Integrity and independence of controls for tank filling
- Fire Safe Shut-Off Valves close to tank on inlet and outlet
- Remotely Operated Shut Off Valves should fail safe
- Joints in bunds must be capable of resisting fire
- Tertiary containment measures to prevent uncontrolled escape of firewater and other products
- Effective shift/crew handover communication

Hertfordshire Fire and Rescue Service Report

- ❑ Launched just last week (8th November).
- ❑ Step-by-step examination of the incident response.
- ❑ Recommendations:
 - System to maintain accurate record of fire responders at scene
 - Consideration of type, quantity and duration of deployment of national resources
 - Earpieces to enable communication while wearing a helmet
 - National system of incident command support teams for deployment during catastrophic or protracted incidents

Summary of Findings and Recommendations

- ❑ Investigation still not completed.
- ❑ Focus of attention on preventing loss of primary containment.
- ❑ Overfilling more likely to produce explosive mixture than pooling from low level release.
- ❑ Site Layout and Location and protection of emergency facilities.
- ❑ Review of guidance on handling and storing flammable liquids.
- ❑ Review of emergency response to incidents.
- ❑ Land use planning.



30a Westland Square, Pearse Street, Dublin 2.

Tel: + 353 - 1 - 677 0733

Fax:+ 353 - 1 - 677 0729

Email: tom.leonard@boc.ie

www.boc.ie